FPSS Fire Protection Survey Services

CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

Township of Wellesley Fire Department

F.S.#1 Linwood (7) F.S.#2 – St Clements (7) F.S #3 Wellesley (7)

Date Test Passed: June 24th 2023

Residential and Industrial Certification (6)

Flow Achieved: __657__ I.G.P.M Liters Per Min: __2987__ Two (2) Hour Test Time

Signed: _*Meliosa Rose*_ Melissa Rose – Principal This Certificate is valid for 5 years and expires June 25th 2028